

FORT DETRICK
Paint Shop
Inspection Checklist

Facility _____ Area _____
Inspector _____ Date _____

	<u>Yes</u>	<u>No</u>
1. Is the paint shop in a specially constructed and isolated fire-resistant room or building?	_____	_____
2. Have personnel been specifically instructed in hazards encountered in painting?	_____	_____
3. Are floors, equipment, and other exposed surfaces kept clean?	_____	_____
4. Is the ventilation provided adequate to remove flammable and injurious substances from the atmosphere?	_____	_____
5. Do personnel wear proper respirators while spray painting?	_____	_____
6. Are precautions taken to ensure that there is no clogging, leaking, or rupturing of the hose lines?	_____	_____
7. Is the air pressure checked frequently to see that it is within a safe limit?	_____	_____
8. Are hand-operated stop valves installed in strategic points so that fixed pipes may be shut off quickly?	_____	_____
9. Are booths provided with ample sprinkler heads, which are inspected and cleaned frequently?	_____	_____
10. Have all sources of ignition in the vicinity of paint operations been eliminated?	_____	_____
11. Are all motors, fixtures, switches, and other electrical devices of an approved explosion-proof type?	_____	_____
12. Is smoking expressly prohibited?	_____	_____
13. Are all exhaust ducts boned and grounded and are the exhaust fans of nonferrous metal?	_____	_____
14. Are the right types and sizes of fire extinguishers provided where spray painting is being done?	_____	_____

- | | | |
|---|-----|-----|
| 15. Are rags and waste disposed of daily? | ___ | ___ |
| 16. Have persons employed in paint shops been instructed to wash thoroughly before eating? | ___ | ___ |
| 17. Is the carrying or eating of food in the spraying department prohibited? | ___ | ___ |
| 18. Is protective clothing stored in ventilated metal lockers located outside the paint shop? | ___ | ___ |
| 19. Is paint material stored in a room isolated from the spraying process? | ___ | ___ |
| 20. Is the mixing of paints done in a fire-resistant room provided with drains for spillage? | ___ | ___ |
| 21. Are personnel made aware of health hazards encountered in paint spraying? | ___ | ___ |

Comments:
